

Installation Instructions Darco Turbowent Maxi 400-500

During the installation on the roof take care of safety instructions, which are applied for this type of work. It is recommended to entrust the installation to professionally trained specialist. Turbowent chimney cowls are ideal for outlets of chimneys exhausting gas boilers fumes. The cowls are designed to withstand temperatures up to 150°C.

Attention:

To unpack the chimney cowl pull it out gently by the little plastic ball. During the transport and installation it is necessary to manipulate with the turbine with care. An inappropriate manipulation could cause cowls deformation or damage. This fact can later cause problems with the head's rotation and make the chimney cowl less effective.

How to install Your Darco Turbowent Maxi:

1. Place the ventilation turbine at the air duct outlet.
2. Center the ventilation turbine located at the air duct outlet.
3. Locate the installation holes located around the lower edge of the turbine neck.
4. Using suitable installation material and tools, attach the turbine through the installation holes to the duct opening.

The turbine or metal pipe under the turbine as a conductive roof element, must be earthed accordingly to the standards.

Dismantling instruction:

During the removing of the turbine act in the reverse way than during the installation. Take the turbine down from the roof and liquidate it accordingly to bellow mentioned instructions.

Liquidation of the product and packaging:

The stainless steel product, including the paper package, place into the eco collection center.

Producer: Darco Sp. Zo.o, Osiedle 48, 39-206 Pustków, Poland

