

CERTIFICATE FI/40625

Our Ref. HEL-CERT200300136-01

Product Powered roof ventilator

Type ECo200 FLOW

Trademark VILPE

Certificate Holder VILPE Oy

Kauppatie 9

FI-65610 Mustasaari

Finland

Technical information 230V; 50Hz; 170W; 1,40A; 2510r/min; IP54; Class I

Other information

The product is certified according to the following standard(s)

EN 60335-2-80:2003 + A1:2004 + A2:2009 EN 60335-1:2012 + A11:2014 + A13:2017

EN 62233:2008

Validity This certificate is valid until 26 March 2025 provided that the Conditions for FI

> certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is

brought onto market and that the conditions for FI certification are met.

Date of issue 26 March 2020

SGS Fimko Ltd

Signature

Markus Ahvenus

Certification Manager

lleurley Hum



Page 1 of 2

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_condition Attention is drawn to the limitation of liability, indemnification and iurisdiction issues defined therein

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd

Takomotie 8, FI-00380 Helsinki, Finland t. +358 9 696 361 www.sgs.fi



Page 2 of 2 to Certificate: FI/40625

Manufacturer VILPE Oy

Kauppatie 9

FI-65610 Mustasaari

Finland

Manufacturing site VILPE Oy

Kauppatie 9

FI-65610 Mustasaari

Finland

Directive information The certified product(s) fulfils requirements of mentioned standard(s)

which are harmonised under the Low Voltage Directive (2014/35/EU) at

the date of issue of the certificate.

As shown in the Test Report(s) No(s): 297613-1



Page 2 of 2

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd

Takomotie 8, FI-00380 Helsinki, Finland **t.** +358 9 696 361 www.sgs.fi